



Palazzoli

PALAZZOLI S.p.A.

25128 BRESCIA - Italia - Via F. Palazzoli, 31
 Telefono +39 030 2015.1 fax +39 030 2015.258
 http://www.palazzoli.it E-mail: export@palazzoli.it



Approximate image

P491136

**INTERLOCKED PANEL MOUNTING topTER SOCKET 3P+E
 16A 380-415V 50/60Hz 6H IP66/IP67**

Date Declaration of Conformity	20.141.103
Certificate code	CERT_RETIE_05937 CERT_UKR_UA.PN.066.0197-13
Hole type	-
Protection level	IP66/IP67
Clock Position (h)	6
Insulating Voltage	690V
Standard family	FN_PRBL_SD
Nominal current	16A
Reference Standards	EN 60309-1/A1: 2007 EN 60309-1/A1EC: 2014 EN 60309-1/A2: 2012 EN 60309-1: 1999 EN 60309-2/A1: 2007 EN 60309-2/A2: 2012 EN 60309-2: 1999 EN 60309-4/A1: 2012 EN 60309-4: 2007
Directive	2014/35/UE
Insulation Class	II

CE	CE
Dimensions	103X230X123 mm
Frequency	50-60Hz
Poles	3P+E
Nominal Operating Voltage	400V
Manufacturing Material	Thermoplastic
Width	108 mm
Execution	BOARD
Protection	NONE

Marks	CE RETIE UKR
--------------	--------------------





Palazzoli

PALAZZOLI S.p.A.

25128 BRESCIA - Italia - Via F. Palazzoli, 31
 Telefono +39 030 2015.1 fax +39 030 2015.258
 http://www.palazzoli.it E-mail: export@palazzoli.it



Approximate image

P579710

WALL MOUNTED BOTTOM BASE FOR topTER
 INTERLOCKED SOCKETS IP66-IP67

Date Declaration of Conformity	20.120.402	CE	CE
Certificate code	CERT_RETIE_05435 CERT_UKR_UA.PN.066.0197-13	Dimensions	108X260X78 mm
Window type	-	Hole type	-
Number of entries in enclosure	-	Protection level	IP66/IP67
Manufacturing Material	Thermoplastic	Standard family	FN_Q_V
Execution	WALL MOUNTING	Reference Standards	EN 62208: 2011-10
Outfit	-	Directive	2014/35/UE
Marks	CE RETIE UKR	Insulation Class	II

